



# TOWN OF LEDYARD CONNECTICUT

741 Colonel Ledyard Highway  
Ledyard, CT 06339-1511  
(860) 464-8740  
(Fax) (860) 464-1126  
WWW.TOWN.LEDYARD.CT.US

March 16, 2006

## MEMORANDUM

To: Inland Wetlands & Watercourses Commission  
From: Steve Masalin, Public Works Director/Town Engineer *sm*  
Subject: 83 Inchcliffe Drive (appl. #6-06)

I have reviewed the plans for the subject application. The applicant must install bituminous curbing as necessary (approximately 200 linear feet) to direct stormwater past the frontage of the proposed residence to an appropriate discharge location. The curbing must be complete with loam backfill and turf establishment. The plans should be revised accordingly, including a note to the effect that any necessary field adjustments for drainage will be made by the applicant at his cost. The curbing and any other necessary drainage improvements shall be addressed by the Driveway Permit application, and must be completed for Certificate of Occupancy (CO).